

# Schedule of Accreditation

issued by

## United Kingdom Accreditation Service

21 - 47 High Street, Feltham, Middlesex, TW13 4UN, UK

 <p>UKAS TESTING 4613</p> <p>Accredited to ISO/IEC 17025:2005</p>	<h3>Regroup (Reclaim) Limited</h3> <p>Issue No: 006    Issue date: 24 April 2012</p>	
	<p>Air Street Bankside Hull East Yorkshire HU5 1RR</p>	<p>Contact: Mr A Hopkin Tel: +44 (0)1482 879666 Fax: +44 (0)1482 879676 E-Mail: info@regroup.uk.com Website: www.regroup.uk.com</p>
<p><b>Testing performed at the above address only</b></p>		

### DETAIL OF ACCREDITATION

Materials/Products tested	Type of test/Properties measured/Range of measurement	Standard specifications/ Equipment/Techniques used
Petroleum and Petroleum Products Fuel Oil	<p><u>Chemical Tests</u></p> <p>Flash Point</p> <p>Strong Acid Number</p> <p>Total Sediment</p> <p>Water Content</p> <p><u>Sampling</u></p> <p>Manual sampling</p>	<p>IP 523/05 BS EN ISO 3679:2004 Rapid equilibrium closed cup method</p> <p>BS 2000-139:1998 IP 139/1998</p> <p>IP 375/11 ISO 10307-1:2009</p> <p>IP 74/2000 ISO 3733:1999 Distillation method</p> <p>In-house method SOP L54 based on IP 475/05 and ISO 3170:2004</p>
Burner Fuels Derived from Waste Mineral Oils	<p><u>Chemical Tests</u></p> <p>Chlorine content</p> <p>Metal content: Pb, Ni, Cr, Cu, Zn, As, Cd, Ti, Sb, Co, Mn and V</p> <p>Sulphated Ash</p> <p>Sulphur content</p>	<p>IP 503/04 and in house method SOP L71 by WDXRF</p> <p>IP 593/11 and in house method SOP L70 by WDXRF</p> <p>IP 550/08</p> <p>ASTM D2622/10 and in house method SOP L73 by WDXRF</p>
<p>END</p>		